



## HEATING PROCEDURE CERTIFICATE FOR SUBFLOOR WITH UNDERFLOOR HEATING

TO BE COMPLETED BY THE INVESTOR (CONSTRUCTION SUPERVISION INSPECTOR)  
– concerns one room: (e.g. living room, kitchen, other...)

**Place of installation:**

a) flat       b) house       c) other .....

Address: .....

DAY	SET AT TEMP.	NOTES	DATE	SIGNED
1.	20°C – 68°F			
2.	30°C – 86°F			
3.	40°C – 104°F			
4.	50°C – 122°F			
5.	50°C – 122°F			
6.	50°C – 122°F			
7.	50°C – 122°F			
8.	50°C – 122°F			
9.	50°C – 122°F			
10.	50°C – 122°F <small>(or maximum system operating temperature)</small>			
11.	50°C – 122°F			
12.	50°C – 122°F			
13.	50°C – 122°F			
14.	50°C – 122°F			
15.	50°C – 122°F			
16.	40°C – 104°F			
17.	30°C – 86°F			
18.	20°C – 68°F			
19.	Turn off heating			
20.				
21.				
22.				
23.				
24.	20°C – 68°F			
25.	30°C – 86°F			
26.	40°C – 104°F			
27.	50°C – 122°F			
28.	40°C – 104°F			
29.	30°C – 86°F			
30.	20°C – 68°F			

.....  
Date and signature of fitter.  
Stamp of company responsible for assembly.

.....  
Date and legible signature of Investor  
(Supervising Inspector)

**INFORMATION FOR THE INVESTOR:**

Barlinek USA Corp. bears no responsibility for assembly carried out contrary to the Assembly Instructions.  
Additional information concerning the warranty is available on [www.us.barlinek.com](http://www.us.barlinek.com)  
BARLINEK USA Corp, 5881 Glenridge Drive, Suite 130, Atlanta, GA 3028  
e-mail: [info.usa@barlinek.com](mailto:info.usa@barlinek.com)

For multiple choice questions, select correct option as applicable.  
Making false statements on the certificate may constitute grounds for terminating the cooperation agreements.  
This document is drawn up in 2 copies: 1 for the investor, 1 for the fitter.